



**ERRATUM
TO
RULES
AND
REGULATIONS
OF THE
KENT COUNTY WATER AUTHORITY**

Section 3.18 Services:

Subsection 3.18.3 shall be deleted in its entirety and replaced with the paragraph below.

- 3.18.3 Water services shall be located along the frontage of the property that borders the roadway of the recorded street address for the property. In situations where the property has frontage on more than one roadway, then water services may be located along the frontage of the property on either roadway, irrespective of the recorded street address. In situations where a water main does not currently exist across the frontage of the property the water service applicant shall be responsible to extend a full size water main to the property and along the entire frontage of the property. In order to avoid dead end conditions, the main may be required to be extended to complete an Interconnection. This determination will be made by the General Manager/Chief Engineer of the Authority.

APPROVED BY KCWA December 18, 2014