



**ERRATUM
TO
RULES
AND
REGULATIONS
OF THE
KENT COUNTY WATER AUTHORITY**

Section 2.2.11 Subsections 2.2.11.2 and 2.2.11.3, shall be modified to comply with DPUC Rules & Regulations Prescribing Standards for Water Utilities, Section IV (A) 1.

2.2.11 Refusal to Provide Service:

- 2.2.11.2 Under no circumstances will water service be supplied to any property located in areas if the system in which system pressure at the point of service connection is currently less than 20 PSI under the normal operating condition.
- 2.2.11.3 Water service shall not be supplied to any property located in an area of the system in which system pressure at the point of service connection will in the future be less than 20 PSI under normal operating condition.

Policy Memorandum – Pressure Gradient Service elevation limit, approval September 18, 2008

IS RESCINDED IN ITS ENTIRETY

APPROVED BY KCWA MARCH 11, 2014