



- \* TRANSITION COUPLING, DRESSER STYLE, TO BE USED ONLY WHEN EXISTING WATER MAIN IS OF DIFFERENT MATERIAL OTHER THAN DUCTILE IRON.
- \* SOLID SLEEVE TO BE RESTRAINED WITH APPROVED RESTRAINT FITTINGS
- \* ONLY TO BE USED WHEN CALCULATED FRICTION LOSS WILL NOT ADVERSELY EFFECT DISTRIBUTION PRESSURE AND FLOW
- \*\* MINIMUM DEPTH OF COVER SHALL BE 2'-0". THE WATER PIPE SHALL BE CLASS 54 AND INSULATED WITH 2" FOAMGLASS INSULATION W/ PITT WRAP OR EQUAL WHERE THE WATER PIPE HAS LESS THAN 5' OF COVER

KENT COUNTY WATER AUTHORITY  
**WATER MAIN HORIZONTAL OR  
 VERTICAL RELOCATION**

**KCWA**  
 "proudly serving"

NOT TO SCALE

DATE: 09/2006